

**From:** Goetz, Sujata  
**Sent:** Tuesday, January 28, 2020 3:20 PM  
**To:** Jurek, Shane  
**Subject:** Acceptance Review of LAR To Revise the Dose Consequence Analysis For A Loss Of Coolant Accident (EPID L-2020-LLA-0000)

Dear Mr. Jurek

By letter dated January 2, 2020 (Agencywide Document and Access Management System (ADAMS) Accession No. ML20002B254, Susquehanna Nuclear, LLC submitted a license amendment request (LAR) for Susquehanna Unit 1 and Unit 2. The LAR would modify the current licensing basis for the design basis accident loss of coolant accident analysis, technical specification (TS) 5.5.2, "Primary Coolant Sources Outside Containment."

The purpose of this e-mail is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of this amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the NRC staff to complete its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. Given the lesser scope and depth of the acceptance review as compared to the detailed technical review, there may be instances in which issues that impact the NRC staff's ability to complete the detailed technical review are identified despite completion of an adequate acceptance review. If additional information is needed, you will be advised by separate correspondence.

Based on the information provided in your submittal, the NRC staff has estimated that this licensing request will take approximately 450 hours to complete. The NRC staff expects to complete this review in approximately 12 months which is February 2021. If there are emergent complexities or challenges in our review that would cause changes to the initial forecasted completion date or significant changes in the forecasted hours, the reasons for the changes, along with the new estimates, will be communicated during the routine interactions with the assigned project manager.

These estimates are based on the NRC staff's initial review of the application and they could change, due to several factors including requests for additional information, unanticipated addition of scope to the review, and review by NRC advisory committees or hearing-related activities. Additional delay may occur if the submittal is provided to the NRC in advance or in parallel with industry program initiatives or pilot applications.

If you have any questions, please contact me.

**Sujata Goetz**  
**Project Manager, Susquehanna Steam Electric Station**

**Nuclear Regulatory Commission  
11555 Rockville Pike  
Office of the Nuclear Reactor Regulation  
NRC/NRR/DORL/LPL3  
Office O8F2  
Mailroom O8-B1A  
Rockville, MD 20852-2738  
Washington, DC 20555-0001**

**(o) 301.415.8004**

**(f) 301.415.3313**

**Hearing Identifier:** NRR\_DRMA  
**Email Number:** 417

**Mail Envelope Properties** (BL0PR0901MB3074E5AE8625C950B6C07FB3800A0)

**Subject:** Acceptance Review of LAR To Revise the Dose Consequence Analysis For A  
Loss Of Coolant Accident (EPID L-2020-LLA-0000)  
**Sent Date:** 1/28/2020 3:19:49 PM  
**Received Date:** 1/28/2020 3:19:00 PM  
**From:** Goetz, Sujata

**Created By:** Sujata.Goetz@nrc.gov

**Recipients:**  
"Jurek, Shane" <Shane.Jurek@talenergy.com>  
Tracking Status: None

**Post Office:** BL0PR0901MB3074.namprd09.prod.outlook.com

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	3150	1/28/2020 3:19:00 PM

**Options**  
**Priority:** Normal  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**