



**UNITED STATES  
NUCLEAR REGULATORY COMMISSION**

REGION I  
2100 RENAISSANCE BOULEVARD, SUITE 100  
KING OF PRUSSIA, PENNSYLVANIA 19406-2713

December 13, 2021

Mr. Brad Berryman  
Senior Vice President and Chief Nuclear Officer  
Susquehanna Nuclear, LLC  
769 Salem Blvd  
Berwick, PA 18603

SUBJECT: SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2 – DESIGN  
BASIS ASSURANCE INSPECTION (PROGRAMS) INSPECTION REPORT  
05000387/2021010 AND 05000388/2021010

Dear Mr. Berryman:

On November 19, 2021, the U.S. Nuclear Regulatory Commission (NRC) completed an inspection at Susquehanna Steam Electric Station, Units 1 and 2 and discussed the results of this inspection with Mr. Kevin Cimorelli, Site Vice President, and other members of your staff. The results of this inspection are documented in the enclosed report.

No findings or violations of more than minor significance were identified during this inspection.

This letter, its enclosure, and your response (if any) will be made available for public inspection and copying at <http://www.nrc.gov/reading-rm/adams.html> and at the NRC Public Document Room in accordance with Title 10 of the *Code of Federal Regulations* 2.390, "Public Inspections, Exemptions, Requests for Withholding."

Sincerely,

Mel Gray, Chief  
Engineering Branch 1  
Division of Operating Reactor Safety

Docket Nos. 05000387 and 05000388  
License Nos. NPF-14 and NPF-22

Enclosure:  
As stated

cc w/ encl: Distribution via LISTSERV®

SUBJECT: SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2 – DESIGN BASIS ASSURANCE INSPECTION (PROGRAMS) INSPECTION REPORT 05000387/2021010 AND 05000388/2021010 DATED DECEMBER 13, 2021

**DISTRIBUTION:**

JGreives, DORS  
 LCasey, DORS  
 EGarcia, DORS  
 CHighley, DORS, SRI  
 MRossi, DORS, RI  
 DHochmuth, DORS, AA  
 RWilliams, RI OEDO  
 RidsNrrPMSusquehanna Resource  
 RidsNrrDorLp1 Resource

DOCUMENT NAME: G:\DRS\Engineering Branch 2\Kern\2021 Inspections\SSESS POV IR 2021-010.docx

**ADAMS ACCESSION NUMBER: ML21347A036**

|  |          |   |          |   |  |
|--|----------|---|----------|---|--|
| <input checked="" type="checkbox"/> SUNSI Review |          | <input checked="" type="checkbox"/> Non-Sensitive<br><input type="checkbox"/> Sensitive |          | <input checked="" type="checkbox"/> Publicly Available<br><input type="checkbox"/> Non-Publicly Available |  |
| OFFICE   | RI/DORS  | RI/DORS   | RI/DORS  |   |  |
| NAME   | DKern    | JGreives  | MGray    |   |  |
| DATE   | 12/10/21 | 12/10/21  | 12/13/21 |   |  |

OFFICIAL RECORD COPY

**U.S. NUCLEAR REGULATORY COMMISSION  
Inspection Report**

Docket Numbers: 05000387 and 05000388

License Numbers: NPF-14 and NPF-22

Report Numbers: 05000387/2021010 and 05000388/2021010

Enterprise Identifier: I-2021-010-0027

Licensee: Susquehanna Nuclear, LLC

Facility: Susquehanna Steam Electric Station, Units 1 and 2

Location: Berwick, PA

Inspection Dates: November 1, 2021 to November 19, 2021

Inspectors: P. Cataldo, Senior Reactor Inspector  
M. Farnan, Mechanical Engineer  
D. Kern, Senior Reactor Inspector

Approved By: Mel Gray, Chief  
Engineering Branch 1  
Division of Operating Reactor Safety

Enclosure

## **SUMMARY**

The U.S. Nuclear Regulatory Commission (NRC) continued monitoring the licensee's performance by conducting a design basis assurance inspection (programs) inspection at Susquehanna Steam Electric Station, Units 1 and 2, in accordance with the Reactor Oversight Process. The Reactor Oversight Process is the NRC's program for overseeing the safe operation of commercial nuclear power reactors. Refer to <https://www.nrc.gov/reactors/operating/oversight.html> for more information.

### **List of Findings and Violations**

No findings or violations of more than minor significance were identified.

### **Additional Tracking Items**

None.

## INSPECTION SCOPES

Inspections were conducted using the appropriate portions of the inspection procedures (IPs) in effect at the beginning of the inspection unless otherwise noted. Currently approved IPs with their attached revision histories are located on the public website at <http://www.nrc.gov/reading-rm/doc-collections/insp-manual/inspection-procedure/index.html>. Samples were declared complete when the IP requirements most appropriate to the inspection activity were met consistent with Inspection Manual Chapter (IMC) 2515, "Light-Water Reactor Inspection Program - Operations Phase." The inspectors reviewed selected procedures and records, observed activities, and interviewed personnel to assess licensee performance and compliance with Commission rules and regulations, license conditions, site procedures, and standards.

## REACTOR SAFETY

### 71111.21N.02 - Design-Basis Capability of Power-Operated Valves Under 10 CFR 50.55a Requirements

#### Power-Operated Valve Review (IP Section 03) (11 Samples)

The inspectors:

- a. Determined whether the sampled power-operated valves (POVs) are being tested and maintained in accordance with NRC regulations along with the licensee's commitments and/or licensing bases.
- b. Determined whether the sampled POVs are capable of performing their design-basis functions.
- c. Determined whether testing of the sampled POVs is adequate to demonstrate the capability of the POVs to perform their safety functions under design-basis conditions.
- d. Evaluated maintenance activities including a walkdown of the sampled POVs (if accessible).
  - (1) HV01222B, RHRSW - Ultimate Heat Sink Spray Bypass Isolation Valve
  - (2) HV112F073A, RHRSW Loop 'A' Crosstie Valve
  - (3) HV151F028A, RHR Loop 'A' Suppression Pool Spray Test Shutoff Valve
  - (4) HV155F003, HPCS - HPCI Steam Supply Outboard Isolation Valve
  - (5) HV250F046, RCIC Lube Oil Cooler Water Supply Valve
  - (6) HV255F001, HPCI Turbine Steam Supply Valve
  - (7) HV255F006, HPCS - HPCI Injection Valve
  - (8) HV141F022A, 'A' Inboard Main Steam Isolation Valve
  - (9) HV25723, Containment Atmosphere Control - Drywell Air Purge Isolation Valve
  - (10) SV12654A, Containment Instrument Gas - to Main Steam PSV1F013 GJM
  - (11) XV247F010A/B, Control Rod Drive Scram Discharge Volume Vent Valves

## INSPECTION RESULTS

No findings were identified.

## **EXIT MEETINGS AND DEBRIEFS**

The inspectors verified no proprietary information was retained or documented in this report.

- On November 19, 2021, the inspectors presented the design basis assurance inspection (programs) inspection results to Mr. Kevin Cimorelli, Site Vice President, and other members of the licensee staff.

**DOCUMENTS REVIEWED**

| Inspection Procedure | Type  | Designation                                     | Description or Title   | Revision or Date |
|----------------------|---|---|--|------------------|
| 71111.21N.02         | Calculations  | EC-006-0506                                     | HV151F028A Thermal Overload Calculation                                    | Revision 3       |
|                      |   | EC-049-1038                                     | HV151F028A Weak Link Seismic Calculation                                   | Revision 3       |
|                      |   | EC-088-0505                                     | Unit 1 and Unit 2 Class 1E 250 VDC System Voltage Drop Calculation EE5     | Revision 8       |
|                      |   | EC-VALV-0569                                    | V151F028A System Design Basis Calculation                                  | Revision 22      |
|                      |   | EC-VALV-1073                                    | HV151F028A Component Design Basis  | Revision 49      |
|                      |   | EC-VALV-1109                                    | Degradation Assessment Supporting Annual MOV Performance Assessment Report | Revision 13      |
|                      |   | MDS-06  | Verification of Motor-Operated Valve Functionality                         | Revision 18      |
|                      |   | MDS-08  | Periodic Performance Assessment for SSES Motor-Operated Valves             | Revision 13      |
|                      | Corrective Action Documents                           | CR 2021-02179                                   |  |                  |
|                      |   | CR 2021-10413                                   |  |                  |
|                      | Corrective Action Documents Resulting from Inspection | CR 2021-15644                                   |  |                  |
|                      |   | CR 2021-15645                                   |  |                  |
|                      |   | CR 2021-15646                                   |  |                  |
|                      |   | CR 2021-15702                                   |  |                  |
|                      |   | CR 2021-15705                                   |  |                  |
|                      |   | CR 2021-15706                                   |  |                  |
|                      |   | CR 2021-15709                                   |  |                  |
|                      |   | CR 2021-15711                                   |  |                  |
|                      |   | CR 2021-15721                                   |  |                  |
|                      |   | CR 2021-15821                                   |  |                  |
|                      |   | CR 2021-16042                                   |  |                  |
|                      |   | CR 2021-16387                                   |  |                  |
|                      |   | CR 2021-16439                                   |  |                  |
|                      | CR 2021-16461   |   |  |                  |
|                      | Drawings  | M-112   | Unit 1 RHR Service Water System  | Revision 55      |
|                      |   | M-2147  | Unit 2 Control Rod Drive Part B  | Revision 38      |
|                      |   | M-2150  | Unit 2 RCIC Turbine Pump   | Revision 32      |
| Engineering          | EQAR-084  | Limatorque Actuator Environmental Qualification | Revision 23  |                  |

| Inspection Procedure | Type          | Designation        | Description or Title  | Revision or Date |
|----------------------|---------------|--------------------|---|------------------|
|                      | Evaluations   |                    | Assessment Report   |                  |
|                      | Miscellaneous | ASME OMB Code-2006 | 2006 Addenda to ASME OM Code-2004 for Operation and Maintenance of Nuclear Power Plants | 08/31/2006       |
|                      |               | SUS-ISTPLN-100.0   | Unit 1 Inservice Testing Program Plan   | Revision 8       |
|                      |               | SUS-ISTPLN-200.0   | Unit 2 Inservice Testing Program Plan   | Revision 11      |
|                      | Procedures    | NDAP-QA-0017       | Motor Operated Valve Program  | Revision 18      |
|                      |               | NDAP-QA-1170       | Air Operated Valve Program  | Revision 5       |
|                      | Work Orders   | ERPM 1975504       |   |                  |
|                      |               | PCWO 2419208       |   |                  |
|                      |               | RTPM 2014246       |   |                  |